

Typically 12.2m

Typically 3m

Up to 500mm with minimum 100mm

300mm Gravel Base

Concrete Plinth

Typically 2.5m

Typically 2.5m

Typically 2.5m

Typically 3m


Up to 500mm with minimum 100mm

300mm Gravel Base

Concrete Plinth

Typically 12.2m

SCALE



- Notes**
1. Verifying Dimensions: The contractor shall verify dimensions against such other drawings or site conditions as pertain to this part of the work.
 2. Existing Services: Any information concerning the location of existing services (above and below ground) indicated on this drawing is intended for general guidance only. All services should be checked on site prior to any work commencing.
 3. If received electronically it is the recipient's responsibility to print to correct scale. Only written dimensions should be used.
 4. © Crown copyright and database rights 2022 Ordnance Survey 0100031673.

LEGEND

Typical Inverter, containerised style shown but uncontainerised version may also be used. External appearance subject to final design and supplier.

A	Minor amendments	GG	RC	20/02/2023
Rev	Description	By	CB	Date

+44 (0) 208 068 4240
+353 (0) 1 640 0190
www.elgin-energy.com
London | Dublin | Sydney

Project GENERAL

Title TYPICAL INVERTER DETAIL

Status	Drawn By	PM/Checked by
Planning	Gareth Gardener	Elgin
Site Ref	Scale @ A2	Original Date Created
General	1:50	23rd Jan 2023
Drawing Number	Rev	
ELGIN-INVERTER-001	H	

ELGIN-INVERTER-001RevH_230220-(Elgin Inverter Sections)